

By post and by email at ado_np_32@hkfsd.gov.hk

30 July 2021

New Projects Division
Fire Safety Command
Fire Services Department
2/F Centre Parc
11 Sheung Yuet Road
Kowloon Bay

Dear Sir/Madam

**Views from The Hong Kong Institution of Engineers
Regarding the Consultation on the Provision of Sprinkler System for Car Ports
in Hong Kong**

On behalf of the Institution, I am pleased to present to you our views and suggestions as set out in the enclosure for your kind consideration on the captioned subject.

With our expertise and experience, the Institution welcomes the opportunity to work with the Government on the area of concern if and when it is needed.

Thank you.

Yours faithfully



Ir Eva KONG
Director

CKH/EK/SS

Enclosure

Views from The Hong Kong Institution of Engineers Regarding the Consultation on the Provision of Sprinkler System for Car Ports in Hong Kong

The Hong Kong Institution of Engineers (HKIE) would like to provide the following views regarding the consultation on the provision of sprinkler system for car ports in Hong Kong for the Fire Services Department (FSD)'s consideration:

2. The Institution supports the requirement of the inclusion of sprinkler system in all initial building plans for car ports with a total floor areas of more than 230 m², in the belief that the FSD will also impose other relevant Fire Service Installations (FSI) as stipulated in Clause 4.9 and Clause 4.26 respectively for car ports and garages in the Code of Practice for Minimum Fire Service Installations and Equipment issued by the FSD (April 2012 version), such as fire hydrant/ hose reel system (FH/HR system).